




Re: FW: Pineview Septic System 

Aaron Setran to: David Wallis

06/23/2009 08:37 AM

 Aaron Setran *more good news about Pineview.....jezzzzzzzzzz. Aaron Carr Setran*

more good news about Pineview.....jezzzzzzzzzz.

Aaron Carr Setran
U.S. EPA, Water Division
75 Hawthorne St.
San Francisco, CA 94105
(415) 972-3457

"David Wallis" <DWallis@rcac.org>

"David Wallis" <DWallis@rcac.org>

06/22/2009 11:21 AM

To Aaron Setran/R9/USEPA/US@EPA

cc

Subject FW: Pineview Septic System

Aaron,

I just finished a lengthy conversation with Tom Robinson. It looks as if PTP has backed out of the situation completely.

I will share the conversation that I had with Tom ,with you next time we talk. Tom seems to be a very concerned individual and is trying to do the right thing

Tom, stated he would get the two items of information that I requested from the factory within the next two days

I'll work on completing the report regardless and amend any changes –if I receive pertinent info

Dave

From: Thomas Robinson [REDACTED] b6

Sent: Tuesday, June 16, 2009 8:31 AM

To: David Wallis

Cc: landersen@biomicrobics.com

Subject: Pineview Septic System

David:

Just a note to let you know I have been in contact with Bio-Microbics concerning the lab results from Pineview and that I will have a crew there on Wed. June 17 to start installing inspection/sampling ports. I will be requesting a meeting with Wet Labs early next week to review their testing procedures and provide the sampling criteria required by the factory.

Also, at this time both systems A1 & A2 are turned off and the effluent has been sent to system B1.

The flowmeter for A2 has not been operating properly and has been removed and sent to the factory for repairs. We hope to replace and have the sysem operating within 2 weeks.

Previously, PTP Corporation, the original owners, has authorized and paid for all service, maintenance, and repairs for all three systems. Currently, Pineview Homeowners Association is in charge and is very reluctant to pay for *any repairs or service*. I will at my expense install the proper sampling ports and will continue under contract to do routine maintenance. However, repairs, pumping, and additional equipment will have to be presented to the Homeowner's Board for approval.

Please call so we can discuss the system at Pineview.

Tom Robinson
Owner
Knox Excavating/Western Septic Products

(b6 cell
(775)-783-4347 office
(775)-783-9295 fax

This email and any attached files are confidential and intended solely for the intended recipient(s). If you are not the named recipient you should not read, distribute, copy or alter this email. Any views or opinions expressed in this email are those of the author and do not represent those of the RCAC company. Warning: Although precautions have been taken to make sure no viruses are present in this email, the company cannot accept responsibility for any loss or damage



that arise from the use of this email or attachments.